



ULTRAFLEX CONTROL SYSTEMS s.r.l.



Dichiarazione di Prestazioni

DoP n. 36308

1. Sigla di identificazione del prodotto: C-SV 4 A
2. Scopo del prodotto: Unità di alimentazione elettrica destinata all'uso in sistemi di evacuazione fumo e calore
3. Costruttore: Ultraflex Control Systems srl
via XXV Aprile, 45
16012 Busalla (GE), Italy
4. Sistema AVPC: 1
5. Norma armonizzata di rif.: EN 12101-10:2005 + AC:2007
Organismo notificato: ift Rosenheim NB-No. 0757

6. Prestazioni dichiarate:

Caratteristiche essenziali	Classe	Specifiche tecniche armonizz.
Affidabilità operativa	Re 1000	Paragrafi 6 e 7 EN 12101-10:2005 + AC:2007
Parametri funzionali in caso di incendio	Classe funzionale B	Paragrafi 4.1 e 5.2.1 EN 12101-10:2005+ AC:2007
Tempo di risposta	Alimentazione da sorgente secondaria: 20 A $\geq$ 180 sec dopo 72h in standby	Paragrafi 4.1, 5.2.1, 6.2.2 e 6.3.1 EN 12101-10:2005+ AC:2007

7. Le prestazioni del prodotto sopra identificato sono conformi a quelle dichiarate. Questa dichiarazione è rilasciata in accordo con il Regolamento Europeo n. 305/2011, sotto l'esclusiva responsabilità del costruttore sopra identificato. Firmato in rappresentanza del costruttore da

Francesca Gai

Busalla, 25.05.2020



Sede Legale Stab. e Uffici:
Via XXV Aprile, n.45
16012 Busalla (GE) - ITALY
Tel. +39 010 976821
Fax +39 010 9768233
C.F. e P.I.: 03097690105



ULTRAFLEX CONTROL SYSTEMS s.r.l.



Declaration of Performance

DoP n. 36308

8. Unique identification code of the product-type: C-SV 4 A
9. Intended use: Electrical power supply intended to be used in heat and smoke control systems
10. Manufacturer: Ultraflex Control Systems srl
via XXV Aprile, 45
16012 Busalla (GE), Italy
11. System of AVCP: 1
12. Harmonised standard: EN 12101-10:2005 + AC:2007
Notified Body: ift Rosenheim NB-No. 0757

13. Declared performance:

Essential characteristics	Class	Harmonised technical specification	
Operational reliability	Re 1000	Clause 6 and 7 EN 12101-10:2005 + AC:2007	ift
Performance parameters under fire conditions	Functional class B	Clause 4.1 and 5.2.1 EN 12101-10:2005+ AC:2007	ift
Response time	Power supply from secondary power source: 20 A $\geq$ 180 sec after 72h in standby	Clause 4.1, 5.2.1, 6.2.2 and 6.3.1 EN 12101-10:2005+ AC:2007	ift

14. The performance of the product identified above is in conformity with the set of declared performance/s. This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above. Signed for and on behalf of the manufacturer by

Francesca Gai

Busalla, 25.05.2020



Sede Legale Stab. e Uffici:
Via XXV Aprile, n.45
16012 Busalla (GE) - ITALY
Tel. +39 010 976821
Fax +39 010 9768233
C.F. e P.I.: 03097690105